

From: [Crossland, Ronnie](#)
To: [Smalley, Bryant](#)
Cc: [Adams, Adam](#)
Subject: Fwd: ITC Request For Discharge Authorization
Date: Saturday, April 13, 2019 10:12:46 PM
Attachments: [Request For Discharge Authorization.pdf](#)
[ATT00001.htm](#)
[Effluent Limitations and Monitoring Requirements.pdf](#)
[ATT00002.htm](#)

Sent from my iPhone

Begin forwarded message:

From: Kelly Cook <kelly.cook@tceq.texas.gov>
Date: April 13, 2019 at 8:54:35 PM CDT
To: "Crossland, Ronnie (Crossland.Ronnie@epa.gov)" <Crossland.Ronnie@epa.gov>
Cc: "Adams, Adam" <Adams.Adam@epa.gov>
Subject: ITC Request For Discharge Authorization

Ronnie,

TCEQ supports EPA moving forward in approving ITC's April 13, 2019 Request for One-time Authorization of Discharge of Incident Related Wastewater and Continuing Discharge of Non-Incident Related Wastewater as set forth in that request and under the following conditions:

- 1) the bench scale treatability study provided to TCEQ and EPA on April 7, 2019 is representative of the contents of the wastewater treatment storage tank 80-34 which is the subject of ITC's request;
 - 2) any discharge of incident related wastewater complies with TPDES permit no. [0001984000](#), in addition to the limitations in the attached table entitled: *Effluent Limitations and Monitoring Requirements*;
 - 3) TCEQ and EPA will need to provide concurrence after reviewing sampling data of the treated wastewater from tank 80-34 prior to routing any additional waste streams to the wastewater treatment plant including non-incident wastewater; and,
 - 4) ITC has been, and will continue to, diligently pursue additional options to manage the wastewater that has accumulated as a result of the fire suppression efforts in response to the incident that began at the facility on March 17, 2019.
- TCEQ understands that prompt action on this request is necessary to allow an expeditious and controlled means of creating additional storage capacity through treatment and discharge of the tank contents.